



**Mesa Fire and Medical Department
Fire Prevention Division**

Mesa: Inspection Notice

September 27, 2018

VERTUCCIO FARMS
4011 S POWER RD
Mesa, AZ 85212

Congratulations, an inspection of your facility on Sep 27, 2018 revealed no violations.

Inspection Note This inspection record was automatically created by the system in response to a reinspection request from ManageMyInspections.com.

Fire Prevention
20 E Main St., Ste. 650
PO Box 1466
Mesa, AZ 85211-1466
Email: fireprevention@mesaaz.gov

15377 Andrea Enriquez
Inspector

Cono Vertuccio



**Mesa Fire and Medical Department
Fire Prevention Division**

Mesa: Inspection Notice

August 29, 2018

VERTUCCIO FARMS
4011 S POWER RD
Mesa, AZ 85212

An inspection of your facility on Aug 29, 2018 revealed the violations listed below.

ORDER TO COMPLY: Per the adopted City of Mesa Code, the conditions listed are not in compliance with adopted codes and shall be corrected upon receipt of this notice. A re-inspection to determine compliance with this notice shall be conducted on or around Sep 8, 2018.

Failing to comply with this notice may subject you to the penalties provided for by the law for such violations.

Please resolve the issues listed below by the required correction date to avoid further charges. A fee of \$50 will be charged for each inspector site visit beginning with the 3rd visit.

Violations

605.5 Extension cords.

Note Remove extension cords that are not being used for temporary use

605.1 Abatement of electrical hazards.

Note Exposed romex needs to be installed in appropriate conduit, install GFI on pole with weatherproof cover, junction boxes need covers

503.3 Marking.

Note Fire lane signage required

605.6 Unapproved conditions.

Note Breaker boxes need labeling and secure dead man panel

1011.1 Where required.

Note Exit signs and emergency lighting in processing area of farm store needs to be installed

1006.3 Illumination emergency power.

Note Insure backup power for emergency lighting and exits are working properly

Fire Prevention
20 E Main St., Ste. 650
PO Box 1466
Mesa, AZ 85211-1466
Email: fireprevention@mesaaz.gov

A stylized, cursive handwritten signature in black ink, featuring a large initial 'A' followed by a series of loops and a long horizontal flourish.

15377 Andrea Enriquez
Inspector

A cursive handwritten signature in black ink, with a large initial 'C' and 'V' that are clearly legible, followed by a series of loops and a horizontal flourish.

Cono Vertuccio