



Legislation Details (With Text)

File #: 14-1127

Type: Contract

Status: Agenda Ready

In control: City Council

On agenda: 12/1/2014

Title: Purchase of Two Replacement Magnetic Drive Centrifugal Pumps for the Southeast Water Reclamation Plant for the Water Resources Department (Sole Source) (Council District 6)

These pumps will replace two existing pumps that have reached the end of life at the Southeast Water Reclamation Plant (SEWRP), West Tower. The pumps are used to recirculate process water in the plant's primary odor control scrubbers and are important in meeting the compliance standards of the SEWRP Air Quality permit. The original chemical recirculation pumps for the SEWRP were installed with the Odor Reduction Tower in 2001.

Water Resources and Purchasing recommend awarding the contract to sole source vendor, JCH/James, Cooke, & Hobson, Inc., at \$28,488.00. This purchase is funded by the Utility Replacement Extension and Renewal Fund.

Sponsors:

Indexes:

Code sections:

Attachments: 1. Council Report

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Purchase of Two Replacement Magnetic Drive Centrifugal Pumps for the Southeast Water Reclamation Plant for the Water Resources Department (Sole Source) (**Council District 6**)

These pumps will replace two existing pumps that have reached the end of life at the Southeast Water Reclamation Plant (SEWRP), West Tower. The pumps are used to recirculate process water in the plant's primary odor control scrubbers and are important in meeting the compliance standards of the SEWRP Air Quality permit. The original chemical recirculation pumps for the SEWRP were installed with the Odor Reduction Tower in 2001.

Water Resources and Purchasing recommend awarding the contract to sole source vendor, JCH/James, Cooke, & Hobson, Inc., at \$28,488.00. This purchase is funded by the Utility Replacement Extension and Renewal Fund.