

Legislation Text

File #: 20-0712, Version: 1

Three-Year Term Contract with Two Years of Renewal Options for Pad Mounted 3 Phase 15kV SF6 Insulated Switchgear for the Energy Resources Department **(Citywide)**

This contract will provide pad mounted three phase 15 kV load-break interrupting and fault interrupting insulated switchgear. The switchgear is required for the life cycle replacement of the existing Lewis East Substation getaway switches and rebuilding critical portions of the 45-year old substation.

An evaluation committee recommends awarding the contract to the highest-scored proposal from G&W Electric Company, at \$500,000 annually, with an annual increase allowance of up to 5%, or the adjusted Producer Price Index. This purchase is funded by authorized Electric Bond Funds.