




signed: 06/29/23  
expired: 03/31/24

Copyright © 2023 Praxis3, LLC  
All reports, plans, specifications, computer files, field data, notes and other documents  
and correspondence prepared by Praxis3 shall state all common law, statutory and other  
applicable rights and obligations.

This drawing may not be reproduced in whole or in part without written permission of  
Praxis3. It is to be returned upon request. Scales as stated are valid on the original  
drawing.

Rev	Date	Comments
-	06.12.23	Site Lighting



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	AvgMin	Max/Min
CALC POINTS @ 4' ABOVE GRADE	Illuminance	Fc	1.58	11.4	0.0	N.A.	N.A.
PROPERTY LINE @ GRADE	Illuminance	Fc	0.07	0.5	0.0	N.A.	N.A.
GENERAL PARKING	Illuminance	Fc	7.21	11.4	2.3	3.13	4.96
REAR OF LOT	Illuminance	Fc	2.37	9.5	0.0	N.A.	N.A.

Symbol	Qty	Label	Arrangement	Description	Mounting Height	LLD	LLF	Arr. Lum. Lumens	Arr. Watts
■	13	A	Single	MRL-LED-36L-SIL-FT-50-70CR4L-SINGLE	16'	1,000	1,000	22428	254
■	5	B	Single	MRL-LED-36L-SIL-FT-50-70CR1-SINGLE	16'	1,000	1,000	36934	254
■	3	C	Single	MRS-LED-90L-SIL-FT-50-70CR1	16'	1,000	1,000	9308	63
■	1	W	Single	XWM-FT-LED-08L-50	16'	1,000	1,000	8465	64

## Site Lighting Photometric

Sheet Number:

E101